

SUPPLEMENTAL HEATING DEVICE AND WOOD/COAL BURNING STOVE REPORT

COVERAGE CANNOT BE CONSIDERED UNLESS REPORT IS COMPLETED IN ITS ENTIRETY.

Policy No: _____ Date of Insp.: _____
 Applicant: _____ Inspected By: _____
 Address: _____ Agent: _____

1. ATTACH REQUIRED PHOTOS. SEE UNDERWRITING.

2. Wood Stove Mfg. _____ Model # _____ Age of Stove _____
 Installed By: Owner Contractor (Name) _____ Date of Installation _____
 Wood Stove Construction Features: Cast Iron Fire Box Steel Fire Box Fan
 (Check Only Applicable Features): Fire Brick Lining Sand at Bottom
 3. Vent System: a. Masonry With Tile Liner Masonry Without Tile Liner
 b. UL Listed Metal Chimney Single Wall Sheet Metal Triple Wall Sheet Metal
 c. Other _____

Firewood has been seasoned? 1 Year _____ 6 months _____ Not at all _____
 How often is chimney cleaned and by what means? _____


	Yes	No*
4. Is stove free of cracks, broken parts or repairs by welding?	()	()
5. Is stove located on non-combustible floor material? (Type of Material _____)	()	()
6. Does floor protection extend at least 6" from sides and back, and 18" to the side where ashes are removed?	()	()
7. Is stove spaced at least 36" from any combustible material?	()	()
8. Is there at least 18" between top of stove pipe and ceiling or combustible side walls?	()	()
9. Does stove pipe fit snugly into thimble?	()	()
10. Is stove pipe routed so as not to pass through floors, closets, concealed space, or connected to chimney in attic?	()	()
11. Does stove have an automatic draft regulator or built-in damper?	()	()
12. If not, does chimney have a damper located near stove?	()	()
13. Are any other stoves or furnaces vented to the same chimney?	()	()
14. If so, does it enter horizontally at a point higher than outlet of stove firebox?	()	()
15. Does chimney terminate 3' above roof penetration and 2 above any portion of the roof within 10'?	()	()
16. Is Vent pipe or chimney free of creosote deposits?	()	()
17. Does vent system have spark arrestor?	()	()
18. Is woodburning stove vent system equipped with heat reclaiming unit or flue radiator?	()	()
19. If wall covering behind stove is metal or asbestos board, is it installed on one inch spaces to allow air movement behind same?	()	()

* Explain all "No": _____

Information Requested below must be provided.

Complete Diagram: A _____ D _____ G _____ (see #6 above)
 Including B _____ E _____ H _____
 Measurements C _____ F _____

LOCATION OF STOVE:



WALL CONSTRUCTION:

- Solid Brick
- Wood Framed
- Concrete Block
- Other _____

THIMBLE MATERIAL:

- Clay
- Metal
- Other _____

THIMBLE WIDTH (Distance from edge of thimble to stove pipe): _____

INTERIOR PIPE:

- Single Wall
- Double Wall
- Triple Wall